

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power Meter

Name and address of the applicant

Jiangsu Goodwe Power Supply Technology Co., Ltd.
No.90 Zijin Rd, New District, Suzhou, 215011
China

Name and address of the manufacturer

Jiangsu Goodwe Power Supply Technology Co., Ltd.
No.90 Zijin Rd, New District, Suzhou, 215011
China

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional information on page 2Jiangsu Goodwe Power Supply Technology Co., Ltd.
No.90 Zijin Rd, New District, Suzhou, 215011
China

Ratings and principal characteristics

3x230/400Vac, 50Hz/ 60Hz, 5W max
Maximum measured voltage: 300Vac

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HK3000

Additional information (if necessary may also be reported on page 2)

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016, IEC 61010-2-030:2017

National differences:

EU Group Differences, EU Special National Conditions, AU

As shown in the Test Report Ref. No. which forms part of this Certificate

4376680.50 + 4376680.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands