



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA200952

Certificate Holder: Jiangsu Goodwe Power Supply Technology Co., Ltd.
No. 90 ZiJin Road, New District,
Suzhou 215011,
P.R. China

Regulatory Definition: Non-Prescribed
Product Description: Smart Meter (Homekit, Din rail mounted)
Trade Name: GOODWE
Model No.: HK1000
Markings: 100-240Vac 50/60Hz, Max 5W

Standard: AS 61010.1:2003
Conditions: All models approved under this Certificate must comply with the Standard requirements of the end product when installed.

Certification Mark: RCM and SAA200952

Date First Registered: 19 May 2020
Date of Expiry: 19 May 2025

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 19-05-20 200952/1